

CERTIFICATE OF COMPLIANCE

Architectural Surfaces Pental Quartz



9403-420

Certificate Number

21 Sep 2009 - 21 Sep 2023

Certificate Period

Certified

Status

UL 2818 - 2013 Gold Standard for Chemical Emissions for Building Materials, Finishes and Furnishings

Wall finishes are determined compliant in accordance with California Department of Public Health (CDPH) Standard Method V1.2-2017 using a Classroom Environment with an air change of 0.82 hr^{-1} and a loading of 94.60 m^2 ; and Wall finishes are determined compliant in accordance with California Department of Public Health (CDPH) Standard Method V1.2-2017 using an Office Environment with an air change of 0.68 hr^{-1} and a loading of 33.40 m^2 .

Product tested in accordance with UL 2821

Criteria for Building Products and Interior Finishes

CAS Number	Maximum Allowable Predicted Concentration	Units
-	0.22	mg/m ³
50-00-0	9 (7.3 ppb)	µg/m ³
-	0.043	ppm
4994-16-5	6.5	µg/m ³
-	20	µg/m ³
872-50-4	160	µg/m ³
-	1/2 CREL or 1/100th TLV	-